

AURANGABAD MUNICIPAL CORPORATION

FIRE BRIGADE TELPHONE NO-2334000-40FAX No-2331444

Outward No:AMC/FIRE / 1359 /2023

Date 05 / 01 /2023

To,
Podar International School,
Mrs. Rohini Arunrao Narwade,
School Building on Gut No. 41/P,
At. Sunderwadi Ta & Dist Aurangabad.

Sub:- Fire NOC Renewal is issued to the Podar International School, Mrs. Rohini Arunrao Narwade, School Building on Gut No. 41/P,At. Sunderwadi Ta & Dist Aurangabad.

Ref:- 1) Your letter dated 30/12/2019

2) Final Fire NOC On Date 06/01/2020

3) Your Letter dated 05/01/2023

4) CFO Inspection on date 05/01/2023

With Reference to the above subject Fire NOC Renewal is issued to Podar International School, Mrs. Rohini Arunrao Narwade, School Building on Gut No. 41/P, At. Sunderwadi Ta & Dist Aurangabad. Plot area is 4000.00 sq.mtr.

Sr. No	Name of Building	Height of Building	Building No.	No of floors	Total Area of Plot	Built/up area	Noc Fees	Total Rs
1	School Building	08.20 Mtr.	1	G + 1 Floors	4000.00 Sq. Mtr	1760.40 Sq. Mtr	5000	5000

Following Fire prevention and Fire protection & Fire Fighting measures subject to The **School Building** is provided.

- 1. Open space all around the building is provided for the movement of fire tender and which will carry 25 tons. weight capacity.
 - Overhead water tank 2000 lit capacity with the fire pump -450 LPM -01 Nosof suitable capacity for building is provided.
 - 3. 02 Nos. Hose reel of 100 feet on all outlets is provided.
 - 4. Fire Extinguisher of ABC 4 Kg -04 Nos Fire Extinguisher is provided.
 - 5. This Certificate shall be treated valid for a period of one year from the date of issue of Fire Noc.
 - Fire Noc is valide for one year & Noc should be renewed each year.

As per BPMC ACT -1949 section 376, Development control Rules of 1983 and Maharashtra Fire prevention & Life safety Measures Act 2006. Fire NOC Renewal is issued due date 10/01/2023 to the Podar International School, Mrs. Rohini Arunrao Narwade, School Building on Gut No. 41/P, At. Sunderwadi Ta & Dist Aurangabad. Your Fire Noc Next renewal due date 16/01/2024.

Chief Fire Officer

Fire Brigade

Municipal Corporation Aurangabad

Copy to:- A D.T.P AMC, Aurangabad.

Principal
Podar International School
Sundarwadi, Aurangabad