



Pimpri Chinchwad Municipal Corporation
Pimpri, Pune - 411018.
Phone :- 020- 67331110/1120
Fax :- 020- 27425600
E-Mail :- commissioner@pcmcindia.gov.in
Web :- www.pcmcindia.gov.in

NO - ws/lab/321/2024

Date - 18/07/2024

To

The Principal,

Podar International School,


Chinchwad.

Subject: Water sample Potability Certificate.

Drinking water sample provided by Podar International School, Chinchwad on Date: 11/07/2024 was analysed for Chemical and Bacteriological analysis. As per the analysis reports no. ws /lab /318/2024 dated 18/07/2024 & ws /lab /306/2024 dated 12/07/2024 the water Sample is safe for drinking purpose.

The Bacteriological & chemical analysis reports are attached herewith.

Note-The water sample not drawn by this laboratory.


Chief Chemist

Pimpri Chinchwad Municipal Corporation
Pimpri -18

PIMPRI CHINCHWAD MUNICIPAL CORPORATION
(W/S) DIVISION



Report Of Chemical Examination Of Water

NO-WS / LAB / 318 / 2024.

DATE - 18 / 07 / 2024.

NAME - Podar International School.

DATE OF RECEIPT - 11 / 07 / 2024.

ADDRESS - Chinchwad.

DATE OF EXAMINATION - 17 / 07 / 2024.

SOURCE - PCMC Water.

No.	Tests	I. S Standard for Drinking Water	Results mg/lit	Results mg/lit	Conclusion
1	Turbidity	5 N.T.U max	1.59 NTU.		
2	pH	6.5 to 8.5	7.70		
3	Total Hardness (AS CaCo3)	300 mg/lit max	80 mg/lit		
4	Chloride	250 mg/lit max	24 mg/lit		
5	Calcium	75 mg/lit max	24.04 mg/lit		

NOTE-SAMPLE NOT DRAWN BY THIS LABORATORY

COPY TO-


CHIEF CHEMIST
Water Treatment Plant
Pimpri Chinchwad Municipal Corp.
Nigdi, Pune 44

PIMPRI CHINCHWAD MUNICIPAL CORPORATION
(W/S) DIVISION

No-WS/LAB/306/2024

Date-22/07/2024

REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER

NAME - Podar International School DATE OF EXAMINATION -11/7/2024

ADDRESS - Chinchwad

SOURCE -

NO.	WATER SAMPLE (PLACE)	RESIDUAL CHLORINE (PPM)	CONCLUTION MPN/100ml		REMARK
			Coliforms	E.Coll	
1	water sample	Nil	0/100ml	-	potable
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					


CHIEF CHEMIST
Water Treatment Plant
Pimpri Chinchwad Municipal Corp.
Nigdi, Pune 44