

ANNEXURE-C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

File No.: S.D.D.W.O. 18/71/29-25

Date: 29-04-2024

It is certified that an inspection team headed by District wealth and family welfare officer Tumakuru, from Gulur, Tumakuru PHED inspected the Podar International School, Survey No. 176/2 and 28/2, Guluru Village, Kunigal Road, Tumakuru on 23-04-2024 and on the basis of water test report (Attached) bearing no. 15/2024-25 dated 26-04-2024 of Tumakuru (PHED Lab) certified that the Podar International School has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building and the campus as per norms prescribed by the central/state/U.T.Govt.

This certificate is valid for a period of One year (29.04.2024 to 28.04.2025)

Signature with Seal:


Name : Dr. Manjunath.D.N

Designation : DHO

Name & Address of the Office/Department:
District health and family welfare officer,
Amanikere Opp, Tumakuru.

To,
Podar International School,
Survey No. 176/2 & 28/2,
Guluru Village, Kunigal road,
Tumakuru-572118


GENERAL MANAGER
PODAR INTERNATIONAL SCHOOL
KARNATAKA REGION


PRINCIPAL
PODAR INTERNATIONAL SCHOOL
Gulur, Amanikere Village,
Gulur Hobli, Tumakuru-572 118





Tumkur District Water Quality Testing Laboratory

TC-10996

Zilla Panchayath Compound B.H Road Tumkur - 572101, Karnataka.

Email: rdwsd.wqmstp.tumkurdistrictlab@gmail.com

TEST REPORT						
Address of the sampling location: Podar International School Gulur Village, Kunigal Road, Tumkuru Tq, Tumkuru District.				ULR No. : TC109962400000916F		
				Reference: Sample receipt Form		
Contact Number: Podar International School : 6366437892				Sample code: TUM24MAY0916		
				Date of Sample collection: 14/06/2024		
				Sample receipt date: 14/06/2024		
				Analysis start date: 15/06/2024		
				Analysis completion date: 15/06/2024		
Sample Particulars : Drinking Water				Report date: 15/06/2024		
				Sampling Method: APHAMethod		
				Sample quantity: 1 Liter		
Sl. No	Test	Test Method	Acceptable Limit IS 10500 : 2012	Permissible Limit IS 10500 : 2012 RA-2018	Results	Units
Description: Colourless liquid.						
1.	pH Value at 24.8°C	IS 3025 (Part-11) : 2022	6.5 – 8.5	No relaxation	6.52	-
2.	Electrical Conductivity, at 24.8°C	IS 3025 (Part-14) : 2013, 2019	-	-	119	µS/cm
3.	Odour	IS 3025 (Part-5 & 6): 2018	Agreeable	Agreeable	Agreeable	-
4	Taste	IS 3025 (Part-7 & 8): 1983, 2023	Agreeable	Agreeable	-	-
5.	Colour	IS 3025 (Part-4) : 2023	5	15	<5	H _z
6.	Turbidity	IS 3025 (Part-10) : 1984, 2023	1	5	<0.5	NTU
7.	Total Dissolved Solids @ 180°C	IS 3025 (Part-16) : 1984	500	2000	72	mg/l
8.	Alkalinity as CaCO ₃	IS 3025 (Part-23) : 1986, 2023	200	600	28	mg/l
9.	Total Hardness as CaCO ₃	IS 3025 (Part-21) : 2009	200	600	40	mg/l
10.	Calcium as Ca	IS 3025 (Part-40) : 1991	75	200	13	mg/l
11.	Magnesium as Mg	IS 3025 (Part-46) : 1994, 2023	30	100	<5	mg/l
12	Chloride as Cl	IS 3025 (Part-32) : 1988	250	1000	21	mg/l
13.	Sulphate as SO ₄	IS 3025 (Part-24/Sec 1) : 2022	200	400	2	mg/l
14.	Fluoride as F, mg/l	APHA 23 rd Edition 4500- F D	1	1.5	0.25	mg/l
15.	Nitrate as NO ₃ , mg/l	APHA 23 rd Edition 4500- NO ₃ B	45	No relaxation	4.4	mg/l
16.	Iron as Fe, mg/l	IS 3025 (Part-53) : 2003	1	No relaxation	<0.1	mg/l
Remarks: The given sample conforms to the Acceptable limit as per IS 10500: 2012 Drinking Water Specifications for the above tested parameters only.						
 PRINCIPAL				Reviewed & Authorized By  Venkatesh H Technical Manager		

Note: PODAR INTERNATIONAL SCHOOL

Gulur, Apanikara Village
Gulur Hobli, Tumakuru-572 118

• The report shall not be reproduced except in full without the prior approval of the Quality Manager.

• Samples will be discarded after 15 days from the date of report generation.

• Decision rule is applicable as per the procedure mentioned in RDWS/WQMSP/DR-01

RDWS/WQMSP/TeR/01

R.D.W. & S.D.

Water Testing Laboratory

Zilla Panchayath Building,

TUMAKURU - 572 101

GENERAL MANAGER

PODAR INTERNATIONAL SCHOOL

KARNATAKA REGION