



FORM B 13.3

FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/RFOSRT/2021/00002027

Date: 05/03/2024

FSC Safety Certificate Renewal (FSCR) No. FSCA/O/RFOSRT/2021/00002027/R1

Building Occupancy/Category: Educational (non-residential)

To,

KRISHNA INDUSTRIAL SECURITY AND FIRE SERVICES
OPP.MRC COMPANY, NR.NH-08, VILLAGE.TUKWADA VAPI VAPI Valsad 396185
Fire Region: Surat RFO
Mobile No: 9825978709 Email ID: kisfs1@gmail.com

This has reference to your Application No. 2024/00046490 dated 31/01/2024 for Fire Safety Certificate Renewal (FSCR) for the building/premise PODAR INTERNATIONAL SCHOOL (name of the Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: VAPI
5. Name of Block(s): PODAR INTERNATIONAL SCHOOL

The building/premise was inspected on 05/03/2024 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 05/03/2024
2. Six monthly inspection was done on 05/03/2024

The Fire Safety Certificate is renewed for a period of two (2) years upto 05/03/2026 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



Digitally Verified

Digitally verified by: Pathak Hitesh Kumar
Fire Safety Officer - Specialist (FSO-S)
2021/000342

Date: 05/03/2024
Time: 11:57 AM



FSCA/O/RFOSRT/2021/00002027/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.

Principal
Mr. ANUPAM UPADHYAY
Podar International School,
Vapi.

